



NATIONAL
ENVIRONMENTAL
TESTING, INC.

SEP - 7 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

09/01/1998

NET Job Number: 98.05898
Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
216636	OUTFALL 001		08/25/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Project Representative

MIL0004682



NATIONAL
ENVIRONMENTAL
TESTING, INC.

SEP - 7 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

09/01/1998

Job No.: 98.05898

Page 2 of 3

Date Received: 08/25/1998

Job Description: TWICE WEEKLY WASTEWATER

Sample Number / Sample I.D.			Sample Date/ Units	Analyst & Date Analyzed		Reporting Limit
Parameters	Result	Flag			Method	
216636	OUTFALL 001					
Iron, ICP	0.81		mg/L	psc / 08/28/1998	EPA 200.7	<0.10
Lead, ICP	<0.080		mg/L	psc / 08/28/1998	EPA 200.7	<0.080
Silver, ICP	<0.020		mg/L	psc / 08/28/1998	EPA 200.7	<0.020
Zinc, ICP	0.59		mg/L	psc / 08/28/1998	EPA 200.7	<0.020

MIL0004683



COMPANY MILBANK MFG.

ADDRESS 1400 E. HAVENS ST. KOKOMO, IN 46901

PHONE (765) 452-5694

FAX

PROJECT NAME/LOCATION TWICE WEEKLY WASTEWATER

PROJECT NUMBER

PROJECT MANAGER

REPORT TO: RICHARD TYLER

INVOICE TO: _____

P.O. NO. _____

NET QUOTE NO. _____

SAMPLED BY

Michael Meyer

(PRINT NAME)

(PRINT NAME)

SIGNATURE

SIGNATURE

and Type of Containers

ANALYSES

To assist us in selecting the proper method

Is this work being conducted for regulatory compliance monitoring? Yes _____ No _____

Is this work being conducted for regulatory enforcement action? Yes ☐ No ☒

Which regulations apply: RCRA _____ NPDES Wastewater _____
UST _____ Drinking Water _____
Other _____ None _____

COMMENTS

SEP - 7 1998

CONDITION OF SAMPLE: BOTTLES INTACT? YES / NO
FIELD FILTERED? YES / NO

COC SEALS PRESENT AND INTACT? YES/NO
VOLATILES FREE OF HEADSPACE? YES/NO

TEMPERATURE UPON RECEIPT: 2.1°C
Bottles supplied by NET? ☒ YES / NO

SAMPLE REMAINDER DISPOSAL: RETURN SAMPLE REMAINDER TO CLIENT VIA _____
I REQUEST NET TO DISPOSE OF ALL SAMPLE REMAINDERS

DATE _____

RELINQUISHED BY:

DATE _____

TIME

RECEIVED BY:

RELINQUISHED BY:

DATE _____

TIME

RECEIVED FOR NET BY:

METHOD OF SHIPMENT

REMARKS:



NATIONAL
ENVIRONMENTAL
TESTING, INC.

SEP - 7 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

FIELD REPORT

JOB #: 98.05898
CLIENT: MILBANK MFG.
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 8/25/98
SAMPLER(S): MTM

An ISCO model 3710 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, ice, and strainer.

All reusable equipment is decontaminated withalconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 8 hours.

Monitoring start 07:30 on 8/25/98
Monitoring end 15:00 on 8/25/98

The composite sample was cloudy, light brown color.

Notes: Samples were preserved, in the field, in the appropriate containers with any required preservative.